

CE CERTIFICATE

Notified Body No. 0370

No. **0370-CPR-3142**

CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

BUILDING HARDWARE. PANIC EXIT DEVICES OPERATED BY A HORIZONTAL BAR, FOR USE ON ESCAPE ROUTES. REQUIREMENTS AND TEST METHODS

MODEL: **550D + 55M**

CATEGORY OF USE	DURABILITY	DOOR MASS	SUITABILITY FOR USE ON FIRE/SMOKE DOORS	SAFETY	CORROSION RESISTANCE	SECURITY	PROJECTION OF HORIZONTAL BAR	TYPE OF HORIZONTAL BAR OPERATION	FIELD OF DOOR APPLICATION
3	6	5	B	1	3	2	2	A	A

Place on the market under the name of:

OMNİ METALURJİ END. TIC. LTD. ŞTİ.

İMES SAN. SITESİ. A BLOK 102 SOK. No: 3
ESEŖEHİR – DUDULLU, ÜMRANIYE / İSTANBUL (TURKEY)

And produced in the manufacturing plant:

İMES SAN. SITESİ. A BLOK 102 SOK. No: 3
ESEŖEHİR – DUDULLU, ÜMRANIYE / İSTANBUL (TURKEY)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 1125:2008

under system 1 are applied and that **the product fulfils all the prescribed requirements set out above.**

This certificate was first issued on 16th November 2018 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly. It is confirmed on 30th October 2020.

The monitoring assessment will be done before 30th June 2021

Bellaterra, 30th October 2020


LGAI Technological Center, S.A.

Xavier Ruiz Peña
Managing Director, Product Conformity B.U.

You can check the validity of this certificate on our website: www.appluslaboratories.com/certified_products

